

Certificate of Compliance

Certificate:	80069963	Master Contract:	259077
Project:	80125194	Date Issued:	2022-05-28
Issued to:	Altenergy Power System Inc. No.1 Yatai Road Jiaxing, Zhejiang, 314050 CHINA		
Attention:	Kevin Lu		

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: Magic Zhang Magic Zhang

PRODUCTS

CLASS - C531109 - POWER SUPPLIES - Distributed Generation Power Systems Equipment CLASS - C531189 - POWER SUPPLIES - Distributed Generation-Power Systems Equipment - Certified to U.S. Standards

Grid Support Utility Interactive Microinverter, Models DS3-H, DS3, DS3-L and DS3-S, rack mounted.

For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.

APPLICABLE REQUIREMENTS

CSA-C22.2 No.107.1-16	-	Power Conversion Equipment
*UL Std No. 1741-Third Edition	-	Inverters, Converters, Controllers and Interconnection System Equipment
		for Use With Distributed Energy Resources
		(Third Edition, Dated September 28, 2021)



 Certificate:
 80069963

 Project:
 80125194

Master Contract: 259077 Date Issued: 2022-05-28

*<u>Note:</u> Conformity to UL 1741(Third Edition, Dated September 28, 2021) includes compliance with applicable requirements of IEEE 1547-2003 (R2008), IEEE 1547.1-2005(R2011), California Rule 21 and Supplement SA8-SA18.

*Note: This product is PV Rapid Shut Down Equipment and conforms with NEC-2014, NEC-2017 and NEC-2020 Article 690.12 and CEC-2018, CEC-2021 Sec 64-218 Rapid Shutdown of PV Systems, for AC and DC conductors, when installed according manufacturer's instructions.

Notes:

Products certified under Class C531109 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

